

## Alliston Drinking Water System

### Trihalomethane (THM) Testing for Second Quarter 2021

Date	Dugdale Avenue
April 13 <sup>th</sup>	35 µg/l

The Current Running Annual Average (RRA) is 42.3 µg/l based on the last four (4) Quarters (July 2020 – June 2021). The Maximum Acceptable Concentration for THMs is 100 µg/l.

### Haloacetic Acids (HAA) Testing for First Quarter 2021

Date	Beattie Avenue
March 2 <sup>nd</sup>	12.4 µg/l

The Current Running Annual Average (RRA) is 17.2 µg/l based on the last four (4) Quarters (April 2020 – March 2021). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

### Chemical Testing for the Second Quarter of 2021

Date	Nitrite	Nitrate	Iron	Hardness
April 13 <sup>th</sup>	< 0.003 mg/l	0.269 mg/l	100 µg/l	93.5 mg/l

### Microbiological Testing for April 2021

Date	April 4 <sup>th</sup>	April 13 <sup>th</sup>	April 20 <sup>th</sup>	April 27 <sup>th</sup>
Location #1	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #2	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #3	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #4	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #5	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #6	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #7	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #8	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #9	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #10	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform