

# Alliston Drinking Water System

## Trihalomethane (THM) Testing for First Quarter 2022

Date	Dugdale Avenue
January 11 <sup>th</sup>	36 µg/l

The Current Running Annual Average (RRA) is 42.3 µg/l based on the last four (4) Quarters (April 2021 – March 2022). The Maximum Acceptable Concentration for THMs is 100 µg/l.

## Haloacetic Acids (HAA) Testing for Fourth Quarter 2021

Date	Beattie Avenue
December 7 <sup>th</sup>	18.0 µg/l

The Current Running Annual Average (RRA) is 17.8 µg/l based on the last four (4) Quarters (January 2021 – December 2021). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

## Chemical Testing for the First Quarter of 2022

Date	Nitrite	Nitrate	Iron	Hardness
January 11 <sup>th</sup>	< 0.003 mg/l	0.264 mg/l	7 µg/l	88.2 mg/l

## Microbiological Testing for January 2022

Date	January 4 <sup>th</sup>	January 11 <sup>th</sup>	January 18 <sup>th</sup>	January 25 <sup>th</sup>
Location #1	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #2	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #3	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #4	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #5	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #6	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #7	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #8	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #9	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #10	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform