

Alliston Drinking Water System

Trihalomethane (THM) Testing for Third Quarter 2021

| Date | Dugdale Avenue |
|----------------------|----------------|
| July 6 th | 49 µg/l |

The Current Running Annual Average (RRA) is 40.8 µg/l based on the last four (4) Quarters (October 2020 – September 2021). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for Second Quarter 2021

| Date | Beattie Avenue |
|-----------------------|----------------|
| June 22 nd | 15.7 µg/l |

The Current Running Annual Average (RRA) is 17.0 µg/l based on the last four (4) Quarters (June 2020 – July 2021). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Third Quarter of 2021

| Date | Nitrite | Nitrate | Iron | Hardness |
|----------------------|--------------|------------|---------|----------|
| July 6 th | < 0.003 mg/l | 0.234 mg/l | 22 µg/l | 101 mg/l |

Microbiological Testing for July 2021

| Date | July 6 th | July 13 th | July 20 th | July 27 th |
|--------------|----------------------|-----------------------|-----------------------|-----------------------|
| Location #1 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| Location #2 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| Location #3 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| Location #4 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| Location #5 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| Location #6 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| Location #7 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| Location #8 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| Location #9 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| Location #10 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |

E.C. – Escherichia Coli, T.C. – Total Coliform