

## Alliston Drinking Water System

### Trihalomethane (THM) Testing for Fourth Quarter 2021

Date	Dugdale Avenue
October 5 <sup>th</sup>	57 µg/l

The Current Running Annual Average (RRA) is 42.5 µg/l based on the last four (4) Quarters (January 2021 – December 2021). The Maximum Acceptable Concentration for THMs is 100 µg/l.

### Haloacetic Acids (HAA) Testing for Third Quarter 2021

Date	Beattie Avenue
September 7 <sup>th</sup>	25.2 µg/l

The Current Running Annual Average (RRA) is 17.9 µg/l based on the last four (4) Quarters (October 2020 – September 2021). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

### Chemical Testing for the Fourth Quarter of 2021

Date	Nitrite	Nitrate	Iron	Hardness
October 5 <sup>th</sup>	< 0.003 mg/l	0.229 mg/l	7 µg/l	98.6 mg/l

### Microbiological Testing for October 2021

Date	October 5 <sup>th</sup>	October 12 <sup>th</sup>	October 20 <sup>th</sup>	October 26 <sup>th</sup>
Location #1	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #2	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #3	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #4	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #5	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #6	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #7	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #8	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #9	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #10	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform