

### Trihalomethane (THM) Testing for April 2019

Date	Nolan Road	Tottenham Water Tower	Mill Street Reservoir
April 15	74 µg/l	112 µg/l	60 µg/l

The Current Running Annual Average (RRA) is 89.7 µg/l based on the last four (4) Quarters (April 2018 – March 2019). The Maximum Acceptable Concentration for THMs is 100 µg/l.

### Microbiological Testing for April 2019

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
April 1	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
April 8	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
April 15	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
April 23	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
April 29	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

### Chemical Testing for the Second Quarter of 2019

Date	Nitrite	Nitrate	Haloacetic Acids (HAA)	Iron	Hardness
April 15	< 0.003 mg/l	0.034 mg/l	13.7 µg/l	749 µg/l	186 mg/l

Beginning in 2020 HAAs will be calculated using Running Annual Average based on quarterly results over a twelve (12) month period. The Maximum Acceptable Concentration for HAAs is 80 µg/l.