

Trihalomethane (THM) Testing for August 2019

Date	Nolan Road	Tottenham Water Tower	Mill Street Reservoir
August 13	103 µg/l	100 µg/l	47 µg/l

The Current Running Annual Average (RRA) is 91.8 µg/l based on the last four (4) Quarters (July 2018 – June 2019). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Microbiological Testing for August 2019

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
August 6	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 13	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 20	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 27	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

Chemical Testing for the Third Quarter of 2019

Date	Nitrite	Nitrate	Haloacetic Acids (HAA)	Iron	Hardness
July 16	< 0.003 mg/l	0.026 mg/l	10.3 µg/l	657 µg/l	184 mg/l

Beginning in 2020 HAAs will be calculated using Running Annual Average based on quarterly results over a twelve (12) month period. The Maximum Acceptable Concentration for HAAs is 80 µg/l.