

## Tottenham Drinking Water System

### Trihalomethane (THM) Testing for August 2021

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
August 20 <sup>th</sup>	52 µg/l	131 µg/l	106 µg/l	67 µg/l	68 µg/l	121 µg/l	85 µg/l

The Current Running Annual Average (RRA) is 90.0 µg/l based on the last four (4) Quarters (July 2020 – June 2021). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

### Haloacetic Acids (HAA) Testing for Second Quarter 2021

Date	Nolan Road
June 15 <sup>th</sup>	14.1 µg/l

The Current Running Annual Average (RRA) is 16.4 µg/l based on the last four (4) Quarters (July 2020 – June 2021). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

### Chemical Testing for the Third Quarter of 2021

Date	Nitrite	Nitrate	Iron	Hardness
July 6 <sup>th</sup>	< 0.003 mg/l	0.059 mg/l	637 µg/l	191 mg/l

### Microbiological Testing for August 2021

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
August 3 <sup>rd</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 10 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 17 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 24 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 31 <sup>st</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform