

Trihalomethane (THM) Testing for December 2019

Date	Nolan Road	Tottenham Water Tower	Mill Street Reservoir	Dillane Street East	78 Walkem Drive	Pierce Place	Martin Trail
December 16	108 µg/l	120 µg/l	49 µg/l	74 µg/l	60 µg/l	101 µg/l	107 µg/l

The Current Running Annual Average (RRA) is 93.5 µg/l based on the last four (4) Quarters (January 2019 – December 2019). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Microbiological Testing for December 2019

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
December 2	0 EC, 0 TC		0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 9	0 EC, 0 TC		0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 16	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 23	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 30	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

Chemical Testing for the Fourth Quarter of 2019

Date	Nitrite	Nitrate	Haloacetic Acids (HAA)	Iron	Hardness
October 22	< 0.003 mg/l	0.062 mg/l	8.6 µg/l	784 µg/l	171 mg/l

Haloacetic Acids (HAA) Testing for December 2019

Date	Nolan Road	Tottenham Water Tower	Dillane Street East	78 Walkem Drive	Pierce Place	Martin Trail
December 19	20.7 µg/l	22.3 µg/l	16.2 µg/l	11.9 µg/l	20.8 µg/l	21.6 µg/l

The Current Running Annual Average (RRA) is 13.1 µg/l based on the last four (4) Quarters (January 2019 – December 2019). The Maximum Acceptable Concentration for HAAs is 80 µg/l.