

## Trihalomethane (THM) Testing for December 2020

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Sharpe Crescent	78 Walkem Drive	Pierce Place	Martin Trail
December 15 <sup>th</sup>	41 µg/l	107 µg/l	88 µg/l	112 µg/l	101 µg/l	93 µg/l	108 µg/l

The Current Running Annual Average (RRA) is 91.6 µg/l based on the last four (4) Quarters (January 2020 – December 2020). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

## Microbiological Testing for December 2020

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
December 1 <sup>st</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 8 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 15 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 22 <sup>nd</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 29 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

## Haloacetic Acids (HAA) Testing for December 2020

Date	Nolan Road
December 15 <sup>th</sup>	14.3 µg/l

The Current Running Annual Average (RRA) is 16.2 µg/l based on the last four (4) Quarters (January 2020 – December 2020). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

## Chemical Testing for the Fourth Quarter of 2020

Date	Nitrite	Nitrate	Iron	Hardness
October 27 <sup>th</sup>	< 0.003 mg/l	0.037 mg/l	798 µg/l	178 mg/l
December 15 <sup>th</sup>			630 µg/l	