

Tottenham Drinking Water System

Trihalomethane (THM) Testing for December 2021

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
December 14 th	30 µg/l	96 µg/l	76 µg/l	69 µg/l	97 µg/l	79 µg/l	77 µg/l

The Current Running Annual Average (RRA) is 87.3 µg/l based on the last four (4) Quarters (January 2021 – December 2021). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Haloacetic Acids (HAA) Testing for Fourth Quarter 2021

Date	Pierce Place
December 7 th	17.1 µg/l

The Current Running Annual Average (RRA) is 16.3 µg/l based on the last four (4) Quarters (January 2021 – December 2021). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Fourth Quarter of 2021

Date	Nitrite	Nitrate	Iron	Hardness
October 5 th	< 0.003 mg/l	0.058 mg/l	852 µg/l	194 mg/l

Microbiological Testing for December 2021

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
December 7 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 14 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 21 st	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 29 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform