

Tottenham Drinking Water System

Trihalomethane (THM) Testing for February 2021

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
February 16 th	47 µg/l	75 µg/l	96 µg/l	61 µg/l	60 µg/l	109 µg/l	102 µg/l

The Current Running Annual Average (RRA) is 93.2 µg/l based on the last four (4) Quarters (January 2020 – December 2020). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Microbiological Testing for February 2021

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
February 2 nd	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
February 9 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
February 16 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
February 23 rd	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

Haloacetic Acids (HAA) Testing for December 2020

Date	Nolan Road
December 15 th	14.3 µg/l

The Current Running Annual Average (RRA) is 16.2 µg/l based on the last four (4) Quarters (January 2020 – December 2020). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the First Quarter of 2021

Date	Nitrite	Nitrate	Iron	Hardness
January 5 th	< 0.003 mg/l	0.054 mg/l	637 µg/l	176 mg/l