

Trihalomethane (THM) Testing for January 2020

| Date | Nolan Road | Tottenham Water Tower | Mill Street Reservoir | Dillane Street East | 78 Walkem Drive | Pierce Place | Martin Trail |
|------------|------------|-----------------------|-----------------------|---------------------|-----------------|--------------|--------------|
| January 15 | 74 µg/l | 40 µg/l | | 78 µg/l | 40 µg/l | 88 µg/l | 97 µg/l |
| January 20 | 83 µg/l | 114 µg/l | 48 µg/l | 70 µg/l | 54 µg/l | 115 µg/l | 132 µg/l |

The Current Running Annual Average (RRA) is 93.5 µg/l based on the last four (4) Quarters (January 2019 – December 2019). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Samples on January 15th were taken by the MECP as part of their Annual Water Inspection.

Microbiological Testing for January 2020

| Date | Location #1 | Location #2 | Location #3 | Location #4 | Location #5 | Location #6 | Location #7 |
|------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| January 7 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| January 13 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | | 0 EC, 0 TC | 0 EC, 0 TC |
| January 20 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| January 28 | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |

E.C. – Escherichia Coli, T.C. – Total Coliform

Chemical Testing for the First Quarter of 2020

| Date | Nitrite | Nitrate | Haloacetic Acids (HAA) | Iron | Hardness |
|------------|--------------|------------|------------------------|----------|----------|
| January 20 | < 0.003 mg/l | 0.057 mg/l | To be taken in March | 651 µg/l | 172 mg/l |

Haloacetic Acids (HAA) Testing for December 2019

| Date | Nolan Road | Tottenham Water Tower | Dillane Street East | 78 Walkem Drive | Pierce Place | Martin Trail |
|-------------|------------|-----------------------|---------------------|-----------------|--------------|--------------|
| December 19 | 20.7 µg/l | 22.3 µg/l | 16.2 µg/l | 11.9 µg/l | 20.8 µg/l | 21.6 µg/l |

The Current Running Annual Average (RRA) is 13.1 µg/l based on the last four (4) Quarters (January 2019 – December 2019). The Maximum Acceptable Concentration for HAAs is 80 µg/l.