

Trihalomethane (THM) Testing for July 2020

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane Street East	78 Walkem Drive	Pierce Place	Martin Trail
July 13	42 µg/l	134 µg/l	88 µg/l	116 µg/l	63 µg/l	103 µg/l	96 µg/l

The Current Running Annual Average (RRA) is 91.8 µg/l based on the last four (4) Quarters (July 2019 – June 2020). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Microbiological Testing for July 2020

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
July 6	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
July 13	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
July 23	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
July 28	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

Haloacetic Acids (HAA) Testing for June 2020

Date	Nolan Road
June 15	12.5 µg/l

The Current Running Annual Average (RRA) is 14.1 µg/l based on the last four (4) Quarters (July 2019 – June 2020). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Third Quarter of 2020

Date	Nitrite	Nitrate	Iron	Hardness
July 13	< 0.003 mg/l	0.052 mg/l	754 µg/l	182 mg/l