

Tottenham Drinking Water System

Trihalomethane (THM) Testing for July 2021

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
July 13 th	51 µg/l	139 µg/l	116 µg/l	117 µg/l	110 µg/l	84 µg/l	87 µg/l

The Current Running Annual Average (RRA) is 90.0 µg/l based on the last four (4) Quarters (July 2020 – June 2021). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Haloacetic Acids (HAA) Testing for Second Quarter 2021

Date	Nolan Road
June 15 th	14.1 µg/l

The Current Running Annual Average (RRA) is 16.4 µg/l based on the last four (4) Quarters (July 2020 – June 2021). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Third Quarter of 2021

Date	Nitrite	Nitrate	Iron	Hardness
July 6 th	< 0.003 mg/l	0.059 mg/l	637 µg/l	191 mg/l

Microbiological Testing for July 2021

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
July 6 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
July 13 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
July 20 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
July 27 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform