

## Trihalomethane (THM) Testing for June 2020

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane Street East	78 Walkem Drive	Pierce Place	Martin Trail
June 15	53 µg/l	119 µg/l	96 µg/l	76 µg/l	56 µg/l	99 µg/l	85 µg/l

The Current Running Annual Average (RRA) is 91.6 µg/l based on the last four (4) Quarters (July 2019 – June 2020). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

## Microbiological Testing for June 2020

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
June 1	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 8	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 15	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 22	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 29	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

## Haloacetic Acids (HAA) Testing for June 2020

Date	Nolan Road
June 15	12.5 µg/l

The Current Running Annual Average (RRA) is 14.1 µg/l based on the last four (4) Quarters (July 2019 – June 2020). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

## Chemical Testing for the Second Quarter of 2020

Date	Nitrite	Nitrate	Iron	Hardness
April 14	< 0.003 mg/l	0.038 mg/l	688 µg/l	181 mg/l