

## Tottenham Drinking Water System

### Trihalomethane (THM) Testing for June 2021

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
June 8 <sup>th</sup>	40 µg/l	50 µg/l	115 µg/l	67 µg/l	44 µg/l	85 µg/l	78 µg/l

The Current Running Annual Average (RRA) is 90.0 µg/l based on the last four (4) Quarters (July 2020 – June 2021). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

### Haloacetic Acids (HAA) Testing for Second Quarter 2021

Date	Nolan Road
June 15 <sup>th</sup>	14.1 µg/l

The Current Running Annual Average (RRA) is 16.4 µg/l based on the last four (4) Quarters (July 2020 – June 2021). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

### Chemical Testing for the Second Quarter of 2021

Date	Nitrite	Nitrate	Iron	Hardness
April 13 <sup>th</sup>	< 0.003 mg/l	0.056 mg/l	746 µg/l	181 mg/l

### Microbiological Testing for June 2021

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
June 1 <sup>st</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 8 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 15 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 22 <sup>nd</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 29 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform