

### Trihalomethane (THM) Testing for March 2019

Date	Nolan Road	Tottenham Water Tower	Mill Street Reservoir
March 12	94 µg/l	67 µg/l	65 µg/l

The Current Running Annual Average (RRA) is 90.0 µg/l based on the last four (4) Quarters (January 2018 – December 2018). The Maximum Acceptable Concentration for THMs is 100 µg/l.

### Microbiological Testing for March 2019

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
March 4	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
March 12	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
March 18	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
March 26	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

### Chemical Testing for the First Quarter of 2019

Date	Nitrite	Nitrate	Haloacetic Acids (HAA)	Iron	Hardness
January 14	< 0.003 mg/l	0.033 mg/l	10.8 µg/l	711 µg/l	170 mg/l

Beginning in 2020 HAAs will be calculated using Running Annual Average based on quarterly results over a twelve (12) month period. The Maximum Acceptable Concentration for HAAs is 80 µg/l.