

Trihalomethane (THM) Testing for March 2020

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane Street East	78 Walkem Drive	Pierce Place	Martin Trail
March 23	49 µg/l (Mar 27 th)	109 µg/l	105 µg/l	114 µg/l	115 µg/l	83 µg/l	84 µg/l

The Current Running Annual Average (RRA) is 95.7 µg/l based on the last four (4) Quarters (April 2019 – March 2020). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Microbiological Testing for March 2020

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
March 2	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
March 10	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
March 16	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
March 24	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
March 31	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

Haloacetic Acids (HAA) Testing for March 2020

Date	Nolan Road	Tottenham Water Tower	Dillane Street East	78 Walkem Drive	Pierce Place	Martin Trail
March 17	19.5 µg/l	10.4 µg/l	10.9 µg/l	9.5 µg/l	17.6 µg/l	19.7 µg/l

The Current Running Annual Average (RRA) is 14.4 µg/l based on the last four (4) Quarters (April 2019 – March 2020). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the First Quarter of 2020

Date	Nitrite	Nitrate	Iron	Hardness
January 20	< 0.003 mg/l	0.057 mg/l	651 µg/l	172 mg/l