

Tottenham Drinking Water System

Trihalomethane (THM) Testing for May 2021

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
May 11 th	35 µg/l	110 µg/l	74 µg/l	89 µg/l	44 µg/l	68 µg/l	73 µg/l

The Current Running Annual Average (RRA) is 92.3 µg/l based on the last four (4) Quarters (April 2020 – March 2021). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Haloacetic Acids (HAA) Testing for First Quarter 2021

Date	Nolan Road
March 2 nd	13.6 µg/l

The Current Running Annual Average (RRA) is 16.0 µg/l based on the last four (4) Quarters (April 2020 – March 2021). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Second Quarter of 2021

Date	Nitrite	Nitrate	Iron	Hardness
April 13 th	< 0.003 mg/l	0.056 mg/l	746 µg/l	181 mg/l

Microbiological Testing for May 2021

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
May 4 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
May 11 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
May 18 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
May 25 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform