

Trihalomethane (THM) Testing for November 2020

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane Street East	78 Walkem Drive	Pierce Place	Martin Trail
November 17 th	49 µg/l	132 µg/l	92 µg/l	114 µg/l	130 µg/l	103 µg/l	93 µg/l

The Current Running Annual Average (RRA) is 85.6 µg/l based on the last four (4) Quarters (October 2019 – September 2020). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Microbiological Testing for November 2020

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
November 3 rd	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
November 10 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
November 17 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
November 24 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

Haloacetic Acids (HAA) Testing for September 2020

Date	Nolan Road
September 24 th	23.4 µg/l

The Current Running Annual Average (RRA) is 17.4 µg/l based on the last four (4) Quarters (October 2019 – September 2020). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Fourth Quarter of 2020

Date	Nitrite	Nitrate	Iron	Hardness
October 27 th	< 0.003 mg/l	0.037 mg/l	798 µg/l	178 mg/l