

## Trihalomethane (THM) Testing for October 2019

Date	Nolan Road	Tottenham Water Tower	Mill Street Reservoir	Dillane Street East	78 Walkem Drive	Pierce Place	Martin Trail
October 22	103 µg/l	63 µg/l	47 µg/l	60 µg/l	57 µg/l	111 µg/l	123 µg/l

The Current Running Annual Average (RRA) is 95.6 µg/l based on the last four (4) Quarters (October 2018 – September 2019). The Maximum Acceptable Concentration for THMs is 100 µg/l.

## Microbiological Testing for October 2019

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
October 1	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
October 8	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
October 15	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
October 22	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
October 29	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

## Chemical Testing for the Fourth Quarter of 2019

Date	Nitrite	Nitrate	Haloacetic Acids (HAA)	Iron	Hardness
October 22	< 0.003 mg/l	0.062 mg/l	8.6 µg/l	784 µg/l	171 mg/l

Beginning in 2020 HAAs will be calculated using Running Annual Average based on quarterly results over a twelve (12) month period. The Maximum Acceptable Concentration for HAAs is 80 µg/l.