

Trihalomethane (THM) Testing for September 2019

Date	Nolan Road	Tottenham Water Tower	Mill Street Reservoir
September 17	114 µg/l	159 µg/l	80 µg/l

The Current Running Annual Average (RRA) is 95.6 µg/l based on the last four (4) Quarters (October 2018 – September 2019). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Microbiological Testing for September 2019

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
September 3	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
September 10	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
September 17	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
September 24	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform

Chemical Testing for the Third Quarter of 2019

Date	Nitrite	Nitrate	Haloacetic Acids (HAA)	Iron	Hardness
July 16	< 0.003 mg/l	0.026 mg/l	10.3 µg/l	657 µg/l	184 mg/l

Beginning in 2020 HAAs will be calculated using Running Annual Average based on quarterly results over a twelve (12) month period. The Maximum Acceptable Concentration for HAAs is 80 µg/l.