

Alliston Drinking Water System Sodium Results 2022

Date	October 12 th
Hillcrest Well	25.5 mg/L
Well #1	31.9 mg/L
Well #4	33.5 mg/L
Well #5	21.9 mg/L
Well #6	35.5 mg/L
Well #7	7.89 mg/L
Well #8	26.9 mg/L
Parson Road Reservoir	11.8 mg/L

The aesthetic objective for sodium in drinking water is 200 mg/L. The local Medical Officer of Health should be notified when the sodium concentration exceeds 20 mg/L as this can affect people on sodium restricted diets. The most recent results above show some sampling locations are greater than 20 mg/L but lower than the aesthetic objective.

Please note Alliston Distribution Water is a combination of Parsons Road Reservoir and Wells #1, #7 and #8. Wells #4, #5 and #6 are directed to Parsons Road Reservoir with no customer connections.