

Alliston Drinking Water System

Trihalomethane (THM) Testing for Second Quarter 2022

Date	Dugdale Avenue
April 12 th	31 µg/l

The Current Running Annual Average (RRA) is 41.3 µg/l based on the last four (4) Quarters (July 2021 – June 2022). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for Second Quarter 2022

Date	Beattie Avenue
June 7 th	5.8 µg/l

The Current Running Annual Average (RRA) is 15.8 µg/l based on the last four (4) Quarters (July 2021 – June 2022). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Second Quarter of 2022

Date	Nitrite	Nitrate	Iron	Hardness
April 12 th	< 0.003 mg/l	0.258 mg/l	14 µg/l	89.2 mg/l

Microbiological Testing for June 2022

Date	June 7 th	June 14 th	June 21 st	June 28 th
Location #1	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #2	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #3	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #4	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #5	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #6	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #7	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #8	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #9	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
Location #10	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform