

# Alliston Drinking Water System

## Trihalomethane (THM) Testing for First Quarter 2022

Date	Dugdale Avenue
January 11 <sup>th</sup>	36 µg/l

The Current Running Annual Average (RRA) is 42.3 µg/l based on the last four (4) Quarters (April 2021 – March 2022). The Maximum Acceptable Concentration for THMs is 100 µg/l.

## Haloacetic Acids (HAA) Testing for First Quarter 2022

Date	Beattie Avenue
March 1 <sup>st</sup>	14.3 µg/l

The Current Running Annual Average (RRA) is 18.3 µg/l based on the last four (4) Quarters (April 2021 – March 2022). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

## Chemical Testing for the First Quarter of 2022

Date	Nitrite	Nitrate	Iron	Hardness
January 11 <sup>th</sup>	< 0.003 mg/l	0.264 mg/l	7 µg/l	88.2 mg/l

## Microbiological Testing for March 2022

Date	March 1 <sup>st</sup>	March 8 <sup>th</sup>	March 15 <sup>th</sup>	March 22 <sup>nd</sup>	March 29 <sup>th</sup>
<b>Location #1</b>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
<b>Location #2</b>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
<b>Location #3</b>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
<b>Location #4</b>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
<b>Location #5</b>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
<b>Location #6</b>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
<b>Location #7</b>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
<b>Location #8</b>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
<b>Location #9</b>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
<b>Location #10</b>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform