

Tottenham Drinking Water System

Trihalomethane (THM) Testing for April 2022

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
April 12 th	44 µg/l	69 µg/l	93 µg/l	114 µg/l	60 µg/l	86 µg/l	87 µg/l

The Current Running Annual Average (RRA) is 84.8 µg/l based on the last four (4) Quarters (April 2021 – March 2022).
The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Haloacetic Acids (HAA) Testing for First Quarter 2022

Date	Pierce Place
March 1 st	17.9 µg/l

The Current Running Annual Average (RRA) is 17.4 µg/l based on the last four (4) Quarters (April 2021 – March 2022).
The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Second Quarter of 2022

Date	Nitrite	Nitrate	Iron	Hardness
April 12 th	< 0.003 mg/l	0.053 mg/l	706 µg/l	173 mg/l

Microbiological Testing for April 2022

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
April 5 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
April 12 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
April 19 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
April 26 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform