

Tottenham Drinking Water System

Trihalomethane (THM) Testing for December 2022

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
December 20 th	26 µg/l	50 µg/l	37 µg/l	33 µg/l	24 µg/l	34 µg/l	44 µg/l

The Current Running Annual Average (RRA) is 58.1 µg/l based on the last four (4) Quarters (January 2022 - December 2022). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Haloacetic Acids (HAA) Testing for Fourth Quarter 2022

Date	Pierce Place
December 20 th	18.9 µg/l

The Current Running Annual Average (RRA) is 16.9 µg/l based on the last four (4) Quarters (January 2022 – December 2022). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Fourth Quarter of 2022 – Mill Street Reservoir

Date	Nitrite	Nitrate	Iron	Hardness
October 11 th	< 0.003 mg/l	0.147 mg/l	248 µg/l	123 mg/l

Microbiological Testing for December 2022

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
December 6 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 13 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 20 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 28 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform