

Tottenham Drinking Water System

Trihalomethane (THM) Testing for February 2022

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
February 17 th	50 µg/l	64 µg/l	86 µg/l	71 µg/l	53 µg/l	86 µg/l	82 µg/l

The Current Running Annual Average (RRA) is 87.3 µg/l based on the last four (4) Quarters (January 2021 – December 2021). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Haloacetic Acids (HAA) Testing for Fourth Quarter 2021

Date	Pierce Place
December 7 th	17.1 µg/l

The Current Running Annual Average (RRA) is 16.3 µg/l based on the last four (4) Quarters (January 2021 – December 2021). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the First Quarter of 2022

Date	Nitrite	Nitrate	Iron	Hardness
January 11 th	< 0.003 mg/l	0.055 mg/l	713 µg/l	179 mg/l

Microbiological Testing for February 2022

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
February 1 st	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
February 8 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
February 15 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
February 22 nd	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform