

Tottenham Drinking Water System

Trihalomethane (THM) Testing for July 2022

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
July 12 th	26 µg/l	45 µg/l	40 µg/l	35 µg/l	48 µg/l	40 µg/l	36 µg/l

The Current Running Annual Average (RRA) is 82.7 µg/l based on the last four (4) Quarters (July 2021 – June 2022). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Haloacetic Acids (HAA) Testing for Second Quarter 2022

Date	Pierce Place
June 7 th	10.5 µg/l

The Current Running Annual Average (RRA) is 16.5 µg/l based on the last four (4) Quarters (July 2021 – June 2022). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Third Quarter of 2022 – Mill Street Reservoir

Date	Nitrite	Nitrate	Iron	Hardness
July 12 th	< 0.003 mg/l	0.129 mg/l	288 µg/l	141 mg/l

Microbiological Testing for July 2022

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
July 5 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
July 12 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
July 19 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
July 26 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform