

Tottenham Drinking Water System

Trihalomethane (THM) Testing for June 2022

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
June 14 th	24 µg/l	60 µg/l	36 µg/l	49 µg/l	31 µg/l	30 µg/l	30 µg/l

The Current Running Annual Average (RRA) is 82.7 µg/l based on the last four (4) Quarters (July 2021 – June 2022). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Haloacetic Acids (HAA) Testing for Second Quarter 2022

Date	Pierce Place
June 7 th	10.5 µg/l

The Current Running Annual Average (RRA) is 16.5 µg/l based on the last four (4) Quarters (July 2021 – June 2022). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Second Quarter of 2022

Date	Nitrite	Nitrate	Iron	Hardness
April 12 th	< 0.003 mg/l	0.053 mg/l	706 µg/l	173 mg/l
June 7 th			314 µg/l	

Microbiological Testing for June 2022

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
June 7 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 14 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 21 st	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 28 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform