

Tottenham Drinking Water System

Trihalomethane (THM) Testing for November 2022

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
November 15 th	28 µg/l	62 µg/l	48 µg/l	45 µg/l	27 µg/l	47 µg/l	60 µg/l

The Current Running Annual Average (RRA) is 69.0 µg/l based on the last four (4) Quarters (October 2021 – September 2022). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Haloacetic Acids (HAA) Testing for Third Quarter 2022

Date	Pierce Place
September 13 th	20.1 µg/l

The Current Running Annual Average (RRA) is 16.4 µg/l based on the last four (4) Quarters (October 2021 – September 2022). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Fourth Quarter of 2022 – Mill Street Reservoir

Date	Nitrite	Nitrate	Iron	Hardness
October 11 th	< 0.003 mg/l	0.147 mg/l	248 µg/l	123 mg/l

Microbiological Testing for November 2022

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
November 1 st	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
November 8 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
November 15 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
November 22 nd	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
November 29 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform