

Tottenham Drinking Water System

Trihalomethane (THM) Testing for September 2022

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
September 13 th	27 µg/l	55 µg/l	42 µg/l	44 µg/l	30 µg/l	41 µg/l	40 µg/l

The Current Running Annual Average (RRA) is 69.0 µg/l based on the last four (4) Quarters (October 2021 – September 2022). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Haloacetic Acids (HAA) Testing for Third Quarter 2022

Date	Pierce Place
September 13 th	20.1 µg/l

The Current Running Annual Average (RRA) is 16.4 µg/l based on the last four (4) Quarters (October 2021 – September 2022). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Third Quarter of 2022 – Mill Street Reservoir

Date	Nitrite	Nitrate	Iron	Hardness
July 12 th	< 0.003 mg/l	0.129 mg/l	288 µg/l	141 mg/l

Microbiological Testing for September 2022

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
September 6 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
September 13 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
September 20 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
September 27 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform