

Tottenham Drinking Water System

Trihalomethane (THM) Testing for April 2023

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
April 12 th	30 µg/l	48 µg/l	38 µg/l	47 µg/l	29 µg/l	40 µg/l	38 µg/l

The Current Running Annual Average (RRA) is 47.3 µg/l based on the last four (4) Quarters (April 2022 – March 2023). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Haloacetic Acids (HAA) Testing for First Quarter 2023

Date	Pierce Place
March 14 th	13.7 µg/l

The Current Running Annual Average (RRA) is 15.8 µg/l based on the last four (4) Quarters (April 2022 – March 2023). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Second Quarter of 2023 – Sample Date April 12th

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.171 mg/l	
Iron	218 µg/l	182 µg/l
Hardness	137 mg/l	140 mg/l

Microbiological Testing for April 2023

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
April 4 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
April 12 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
April 18 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
April 25 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform