

Tottenham Drinking Water System

Trihalomethane (THM) Testing for August 2023

Date	Nolan Road	Martin Trail
August 15 th	58 µg/l	48 µg/l

The Current Running Annual Average (RRA) is 40.7 µg/l based on the last four (4) Quarters (July 2022 – June 2023). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for Second Quarter 2023

Date	Pierce Place
June 27 th	11.0 µg/l

The Current Running Annual Average (RRA) is 15.9 µg/l based on the last four (4) Quarters (July 2022 – June 2023). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Third Quarter of 2023 – Sample Date July 11th

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.050 mg/l	
Iron	181 µg/l	126 µg/l
Hardness	153 mg/l	153 mg/l

Microbiological Testing for August 2023

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
August 1 st	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 8 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 15 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 22 nd	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 31 st	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform