

Tottenham Drinking Water System

Trihalomethane (THM) Testing for December 2023

Date	Nolan Road	Martin Trail
December 12 th	34 µg/l	34 µg/l

The Current Running Annual Average (RRA) is 42.0 µg/l based on the last four (4) Quarters (January 2023 – December 2023). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for Fourth Quarter 2023

Date	Pierce Place
December 12 th	19.2 µg/l

The Current Running Annual Average (RRA) is 16.1 µg/l based on the last four (4) Quarters (January 2023 – December 2023). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Fourth Quarter of 2023 – Sample Date October 17th

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.137 mg/l	
Iron	382 µg/l	153 µg/l
Hardness	139 mg/l	143 mg/l

Microbiological Testing for December 2023

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
December 5 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 12 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 19 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
December 27 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform