

# Tottenham Drinking Water System

## Trihalomethane (THM) Testing for January 2023

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
January 10 <sup>th</sup>	29 µg/l	42 µg/l	33 µg/l	32 µg/l	33 µg/l	33 µg/l	32 µg/l

The Current Running Annual Average (RRA) is 58.1 µg/l based on the last four (4) Quarters (January 2022 – December 2022). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

## Haloacetic Acids (HAA) Testing for Fourth Quarter 2022

Date	Pierce Place
December 20 <sup>th</sup>	18.9 µg/l

The Current Running Annual Average (RRA) is 16.9 µg/l based on the last four (4) Quarters (January 2022 – December 2022). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

## Chemical Testing for the First Quarter of 2023 – Mill Street Reservoir

Date	Nitrite	Nitrate	Iron	Hardness
January 10 <sup>th</sup>	< 0.003 mg/l	0.203 mg/l	230 µg/l	129 mg/l

## Microbiological Testing for January 2023

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
January 3 <sup>rd</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
January 10 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
January 17 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
January 24 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
January 31 <sup>st</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform