

# Tottenham Drinking Water System

## Trihalomethane (THM) Testing for July 2023

Date	Pierce Place	Water Tower
July 11 <sup>th</sup>	48 µg/l	43 µg/l

The Current Running Annual Average (RRA) is 40.7 µg/l based on the last four (4) Quarters (July 2022 – June 2023). The Maximum Acceptable Concentration for THMs is 100 µg/l.

## Haloacetic Acids (HAA) Testing for Second Quarter 2023

Date	Pierce Place
June 27 <sup>th</sup>	11.0 µg/l

The Current Running Annual Average (RRA) is 15.9 µg/l based on the last four (4) Quarters (July 2022 – June 2023). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

## Chemical Testing for the Third Quarter of 2023 – Sample Date July 11<sup>th</sup>

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.050 mg/l	
Iron	181 µg/l	126 µg/l
Hardness	153 mg/l	153 mg/l

## Microbiological Testing for July 2023

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
July 4 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
July 11 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 12 TC	0 EC, 0 TC	0 EC, 0 TC
July 18 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
July 25 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform