

Tottenham Drinking Water System

Trihalomethane (THM) Testing for June 2023

Date	Nolan Road	Martin Trail
June 20 th	40 µg/l	40 µg/l

The Current Running Annual Average (RRA) is 40.7 µg/l based on the last four (4) Quarters (July 2022 – June 2023). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for Second Quarter 2023

Date	Pierce Place
June 27 th	11.0 µg/l

The Current Running Annual Average (RRA) is 15.9 µg/l based on the last four (4) Quarters (July 2022 – June 2023). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Second Quarter of 2023 – Sample Date April 12th

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.171 mg/l	
Iron	218 µg/l	182 µg/l
Hardness	137 mg/l	140 mg/l

Microbiological Testing for June 2023

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
June 6 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 13 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 20 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 27 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform