

Tottenham Drinking Water System

Trihalomethane (THM) Testing for March 2023

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
March 14 th	23 µg/l	24 µg/l	35 µg/l	46 µg/l	23 µg/l	35 µg/l	46 µg/l

The Current Running Annual Average (RRA) is 47.3 µg/l based on the last four (4) Quarters (April 2022 – March 2023).
The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Haloacetic Acids (HAA) Testing for First Quarter 2023

Date	Pierce Place
March 14 th	13.7 µg/l

The Current Running Annual Average (RRA) is 15.8 µg/l based on the last four (4) Quarters (April 2022 – March 2023).
The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the First Quarter of 2023 – Mill Street Reservoir

Date	Nitrite	Nitrate	Iron	Hardness
January 10 th	< 0.003 mg/l	0.203 mg/l	230 µg/l	129 mg/l

Microbiological Testing for March 2023

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
March 7 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
March 14 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
March 21 st	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
March 28 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform