

Tottenham Drinking Water System

Trihalomethane (THM) Testing for May 2023

Date	Mill Street Reservoir	Tottenham Water Tower	Nolan Road	Dillane St E	78 Walkem Drive	Pierce Place	Martin Trail
May 9 th	21 µg/l	50 µg/l	41 µg/l	44 µg/l	49 µg/l	35 µg/l	36 µg/l

The Current Running Annual Average (RRA) is 47.3 µg/l based on the last four (4) Quarters (April 2022 – March 2023). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Please note the Mill Street Reservoir is not included in the RAA as it is considered a treated sample not a distribution sample.

Haloacetic Acids (HAA) Testing for First Quarter 2023

Date	Pierce Place
March 14 th	13.7 µg/l

The Current Running Annual Average (RRA) is 15.8 µg/l based on the last four (4) Quarters (April 2022 – March 2023). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Second Quarter of 2023 – Sample Date April 12th

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.171 mg/l	
Iron	218 µg/l	182 µg/l
Hardness	137 mg/l	140 mg/l

Microbiological Testing for May 2023

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
May 2 nd	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
May 9 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
May 16 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
May 23 rd	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
May 30 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform