

Tottenham Drinking Water System

Trihalomethane (THM) Testing for November 2023

Date	Pierce Place	Water Tower
November 14 th	51 µg/l	36 µg/l

The Current Running Annual Average (RRA) is 42.1 µg/l based on the last four (4) Quarters (October 2022 – September 2023). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for Third Quarter 2023

Date	Pierce Place
September 12 th	20.4 µg/l

The Current Running Annual Average (RRA) is 16.0 µg/l based on the last four (4) Quarters (October 2022 – September 2023). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Fourth Quarter of 2023 – Sample Date October 17th

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.137 mg/l	
Iron	382 µg/l	153 µg/l
Hardness	139 mg/l	143 mg/l

Microbiological Testing for November 2023

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
November 7 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
November 14 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
November 21 st	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
November 28 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform