

# Tottenham Drinking Water System

## Trihalomethane (THM) Testing for October 2023

Date	Nolan Road	Martin Trail
October 24 <sup>th</sup>	60 µg/l	49 µg/l

The Current Running Annual Average (RRA) is 42.1 µg/l based on the last four (4) Quarters (October 2022 – September 2023). The Maximum Acceptable Concentration for THMs is 100 µg/l.

## Haloacetic Acids (HAA) Testing for Third Quarter 2023

Date	Pierce Place
September 12 <sup>th</sup>	20.4 µg/l

The Current Running Annual Average (RRA) is 16.0 µg/l based on the last four (4) Quarters (October 2022 – September 2023). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

## Chemical Testing for the Fourth Quarter of 2023 – Sample Date October 17<sup>th</sup>

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.137 mg/l	
Iron	382 µg/l	153 µg/l
Hardness	139 mg/l	143 mg/l

## Microbiological Testing for October 2023

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
October 3 <sup>rd</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
October 10 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
October 17 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
October 24 <sup>th</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
October 31 <sup>st</sup>	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform