

Tottenham Drinking Water System

Trihalomethane (THM) Testing for September 2023

Date	Water Tower	Pierce Place
September 12 th	35 µg/l	61 µg/l

The Current Running Annual Average (RRA) is 42.1 µg/l based on the last four (4) Quarters (October 2022 – September 2023). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for Third Quarter 2023

Date	Pierce Place
September 12 th	20.4 µg/l

The Current Running Annual Average (RRA) is 16.0 µg/l based on the last four (4) Quarters (October 2022 – September 2023). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Third Quarter of 2023 – Sample Date July 11th

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.050 mg/l	
Iron	181 µg/l	126 µg/l
Hardness	153 mg/l	153 mg/l

Microbiological Testing for September 2023

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
September 5 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
September 12 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
September 19 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
September 26 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform