

Tottenham Drinking Water System

Trihalomethane (THM) Testing for Second Quarter 2024

| Date | Pierce Place |
|------------------------|--------------|
| April 16 th | 43 µg/l |

The Current Running Annual Average (RRA) is 43.0 µg/l based on the last four (4) Quarters (July 2023 – June 2024). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for First Quarter 2024

| Date | Pierce Place |
|------------------------|--------------|
| March 12 th | 8.2 µg/l |

The Current Running Annual Average (RRA) is 14.4 µg/l based on the last four (4) Quarters (April 2023 – March 2024). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Second Quarter of 2024 – Sample Date April 16th

| Date | Mill Street Reservoir | Pierce Place |
|----------|-----------------------|--------------|
| Nitrite | < 0.003 mg/l | |
| Nitrate | 0.158 mg/l | |
| Iron | 224 µg/l | 332 µg/l |
| Hardness | 129 mg/l | 129 mg/l |

Microbiological Testing for April 2024

| Date | Location #1 | Location #2 | Location #3 | Location #4 | Location #5 | Location #6 | Location #7 |
|------------------------|-------------|-------------|-------------|-------------|-------------|-------------|-------------|
| April 2 nd | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| April 9 th | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| April 16 th | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| April 23 rd | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |
| April 30 th | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC | 0 EC, 0 TC |

E.C. – Escherichia Coli, T.C. – Total Coliform