

Tottenham Drinking Water System

Trihalomethane (THM) Testing for Third Quarter 2024

Date	Pierce Place
July 17 th	65 µg/l

The Current Running Annual Average (RRA) is 46.5 µg/l based on the last four (4) Quarters (October 2023 – September 2024). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for Second Quarter 2024

Date	Pierce Place
June 12 th	17.0 µg/l

The Current Running Annual Average (RRA) is 17.4 µg/l based on the last four (4) Quarters (July 2023 – June 2024). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Third Quarter of 2024 – Sample Date July 17th

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.138 mg/l	
Iron	237 µg/l	93 µg/l*
Hardness	134 mg/l	136 mg/l*

* Sample Date: July 24th

Microbiological Testing for August 2024

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
August 7 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 14 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 21 st	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
August 28 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform