

Tottenham Drinking Water System

Trihalomethane (THM) Testing for January 2024

Date	Water Tower	Pierce Place
January 30 th	21 µg/l	35 µg/l

The Current Running Annual Average (RRA) is 42.0 µg/l based on the last four (4) Quarters (January 2023 – December 2023). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for Fourth Quarter 2023

Date	Pierce Place
December 12 th	19.2 µg/l

The Current Running Annual Average (RRA) is 16.1 µg/l based on the last four (4) Quarters (January 2023 – December 2023). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the First Quarter of 2024 – Sample Date January 16th

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.165 mg/l	
Iron	155 µg/l	135 µg/l
Hardness	130 mg/l	131 mg/l

Microbiological Testing for January 2024

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
January 2 nd	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
January 9 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
January 16 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
January 23 rd	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
January 30 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform