

Tottenham Drinking Water System

Trihalomethane (THM) Testing for Second Quarter 2024

Date	Pierce Place
April 16 th	43 µg/l

The Current Running Annual Average (RRA) is 43.0 µg/l based on the last four (4) Quarters (July 2023 – June 2024). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for Second Quarter 2024

Date	Pierce Place
June 12 th	17.0 µg/l

The Current Running Annual Average (RRA) is 17.4 µg/l based on the last four (4) Quarters (July 2023 – June 2024). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Second Quarter of 2024 – Sample Date April 16th

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.158 mg/l	
Iron	224 µg/l	144 µg/l*
Hardness	129 mg/l	129 mg/l

* Sample Date: June 12th

Microbiological Testing for June 2024

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
June 5 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 12 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 19 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
June 26 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform