

Tottenham Drinking Water System

Trihalomethane (THM) Testing for March 2024

Date	Water Tower	Pierce Place
March 12 th	45 µg/l	35 µg/l

The Current Running Annual Average (RRA) is 42.5 µg/l based on the last four (4) Quarters (April 2023 – March 2024). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for First Quarter 2024

Date	Pierce Place
March 12 th	8.2 µg/l

The Current Running Annual Average (RRA) is 14.4 µg/l based on the last four (4) Quarters (April 2023 – March 2024). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the First Quarter of 2024 – Sample Date January 16th

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.165 mg/l	
Iron	155 µg/l	135 µg/l
Hardness	130 mg/l	131 mg/l

Microbiological Testing for March 2024

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
March 5 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
March 12 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
March 19 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
March 26 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform