

Tottenham Drinking Water System

Trihalomethane (THM) Testing for Second Quarter 2024

Date	Pierce Place
April 16 th	43 µg/l

The Current Running Annual Average (RRA) is 43.0 µg/l based on the last four (4) Quarters (July 2023 – June 2024). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for First Quarter 2024

Date	Pierce Place
March 12 th	8.2 µg/l

The Current Running Annual Average (RRA) is 14.4 µg/l based on the last four (4) Quarters (April 2023 – March 2024). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Second Quarter of 2024 – Sample Date April 16th

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.158 mg/l	
Iron	224 µg/l	332 µg/l
Hardness	129 mg/l	129 mg/l

Microbiological Testing for May 2024

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
May 7 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
May 14 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
May 21 st	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
May 28 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform