

Tottenham Drinking Water System

Trihalomethane (THM) Testing for Fourth Quarter 2024

Date	Nolan Road	Pierce Place	Martin Trail	Water Tower
October 16 th	68 µg/l	62 µg/l	62 µg/l	63 µg/l

The Current Running Annual Average (RRA) is 51.5 µg/l based on the last four (4) Quarters (January 2024 – December 2024). The Maximum Acceptable Concentration for THMs is 100 µg/l.

Haloacetic Acids (HAA) Testing for Third Quarter 2024

Date	Pierce Place
September 18 th	21.0 µg/l

The Current Running Annual Average (RRA) is 16.4 µg/l based on the last four (4) Quarters (October 2023 – September 2024). The Maximum Acceptable Concentration for HAAs is 80 µg/l.

Chemical Testing for the Fourth Quarter of 2024 – Sample Date October 16th

Date	Mill Street Reservoir	Pierce Place
Nitrite	< 0.003 mg/l	
Nitrate	0.120 mg/l	
Iron	194 µg/l	146 µg/l
Hardness	126 µg/l	132 mg/l

Microbiological Testing for October 2024

Date	Location #1	Location #2	Location #3	Location #4	Location #5	Location #6	Location #7
October 2 nd	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
October 9 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
October 16 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
October 23 rd	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC
October 30 th	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC	0 EC, 0 TC

E.C. – Escherichia Coli, T.C. – Total Coliform